

Fire Alarm and Life Safety System Inspection Certificate

For

Customer Name Has Been
Removed for Privacy
XXXXXXXX
BOSTON, MA 02114

Tested to NFPA 72 Standards

This Inspection was performed in accordance with applicable NFPA Standards. The subsequent pages of this report provide performance measurements, listed ranges of acceptable results, and complete documentation of the inspection. Whenever discrepancies exist between acceptable performance standards and actual test results, notes and/or recommended solutions have been proposed or provided for immediate review and approval.

Inspection Date
Jan 8, 2007

Building: XXXXXX
Contact: XXXXXX
Title: MANAGER

Company: NOREL Service Company, Inc.
Contact: Bryan Ruchala
Title: Technician

Executive Summary

Generated by: *BuildingReports.com*

Building Information								
Building: XXXXXXXX	Contact: XXXXXXXX							
Address: XXXXXXXX	Phone: XXXXXXXX							
Address:	Fax:							
City/State/Zip: BOSTON, MA 02114	Mobile:							
Country: United States of America	Email:							
Inspection Performed By								
Company: Norel Service Company, Inc.	Inspector: Bryan Ruchala							
Address: 16 Cherry Street	Phone: (617) 576-3473							
Address:	Fax:							
City/State/Zip: Cambridge, MA 02139	Mobile:							
Country: United States of America	Email: bruchala@norelservice.com							
System Control Unit								
Manufacturer: Notifier	Inspection Date: 01/08/2007	IDC Style:						
Model Number:	Install Date: 08/01/1996	SLC Style:						
Software Version:	Version Date: 01/08/2007	NAC Style:						
Location: 1st Inside FACP Room	Current Protection: Breaker							
Monitoring								
Type:	Mfg:	Model #:						
Test Time/Date:	Restore Time:							
Inspection Summary								
Category	Total Items		Serviced		Passed		Failed/Other	
	Qty	%	Qty	%	Qty	%	Qty	%
Initiating	39	95%	39	100%	39	100%	0	0%
Control	2	5%	2	100%	2	100%	0	0%
Totals	41	100%	41	100%	41	100%	0	0%
Certification								
Building: XXXXXXXXXXXX	Company: Norel Service Company, Inc.							
Contact: XXXXXXXXXXXXXXXX	Inspector: Bryan Ruchala							
Signed:	Signed:							

Inspection & Testing

Generated by: BuildingReports.com

Building: XXXXXXXXXXXXXXXXXXXX		Control Panel: 1 - Notifier		
<p><i>The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other. Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred.</i></p>				
Device Type	Location	Service	Time	Date
<i>Passed</i>				
Control				
Control Panel	1st Inside FACP Room	Tested	7:16:02 AM	01/08/2007
Initiating				
Duct Detector	2nd Inside Blue Wing Exhibit Stair #9	Tested	11:47:33 AM	01/08/2007
Duct Detector	2nd Inside Blue Wing Exhibit Main Entrance	Tested	11:52:40 AM	01/08/2007
Pull Station	1st Inside Planterium Exhibit	Tested	7:53:22 AM	01/08/2007
Pull Station	1st Inside Blue Wing Exhibit Inside Electric Exhibit	Tested	12:57:04 PM	01/08/2007
Pull Station	1st Inside Computer Place Exhibit Stair #14	Tested	1:13:13 PM	01/08/2007
Pull Station	2nd Inside Blue Wing Exhibit Stair #9	Tested	11:50:10 AM	01/08/2007
Pull Station	2nd Inside Blue Wing Exhibit Stair #10	Tested	11:58:36 AM	01/08/2007
Pull Station	2nd Inside Lighting Exhibit	Tested	12:12:13 PM	01/08/2007
Pull Station	2nd Inside Butterfly Exhibit	Tested	12:18:55 PM	01/08/2007
Smoke Detector	1st Inside Blue Wing Exhibit Main Entrance	Tested	12:39:59 PM	01/08/2007
Smoke Detector	1st Inside Blue Wing Exhibit By Mens Room	Tested	12:41:29 PM	01/08/2007
Smoke Detector	1st Inside Blue Wing Exhibit Mathematica	Tested	12:42:40 PM	01/08/2007
Smoke Detector	1st Inside Blue Wing Exhibit Mathematica	Tested	12:43:30 PM	01/08/2007
Smoke Detector	1st Inside Blue Wing Exhibit Mathematica	Tested	12:43:42 PM	01/08/2007
Smoke Detector	1st Inside Blue Wing Exhibit by Apollo	Tested	12:47:31 PM	01/08/2007
Smoke Detector	1st Inside Blue Wing Exhibit by Apollo	Tested	12:47:36 PM	01/08/2007
Smoke Detector	1st Inside Blue Wing Exhibit Outside Electric Exhibit	Tested	12:53:29 PM	01/08/2007
Smoke Detector	1st Inside Blue Wing Exhibit Inside Electric Exhibit	Tested	1:03:07 PM	01/08/2007
Smoke Detector	1st Inside Blue Wing Exhibit Inside Electric Exhibit	Tested	1:04:05 PM	01/08/2007
Smoke Detector	1st Inside Blue Wing Inside Computer Place Exhibit	Tested	1:05:48 PM	01/08/2007
Smoke Detector	1st Inside Blue Wing Inside Computer Place Exhibit	Tested	1:07:07 PM	01/08/2007
Smoke Detector	1st Inside Blue Wing Inside Computer Place Exhibit	Tested	1:08:18 PM	01/08/2007
Smoke Detector	1st Inside Blue Wing Inside Computer Place Exhibit	Tested	1:09:06 PM	01/08/2007
Smoke Detector	1st Inside Blue Wing Inside Computer Place Exhibit	Tested	1:09:41 PM	01/08/2007
Smoke Detector	2nd Inside Blue Wing Exhibit	Tested	11:31:09 AM	01/08/2007
Smoke Detector	2nd Inside Blue Wing Exhibit 3-D Cinema	Tested	11:32:31 AM	01/08/2007
Smoke Detector	2nd Inside Blue Wing Exhibit Lighting Exhibit	Tested	11:35:02 AM	01/08/2007

Device Type	Location	Service	Time	Date
Smoke Detector	2nd Inside Blue Wing Exhibit at Stair #10	Tested	11:36:16 AM	01/08/2007
Smoke Detector	2nd Inside Blue Wing Exhibit Optical Illusions	Tested	11:37:41 AM	01/08/2007
Smoke Detector	2nd Inside Blue Wing Exhibit Cahners Theater	Tested	11:40:23 AM	01/08/2007
Smoke Detector	2nd Inside Blue Wing Exhibit Cahners Theater	Tested	11:42:40 AM	01/08/2007
Smoke Detector	2nd Inside Blue Wing Exhibit Stair #9	Tested	11:43:38 AM	01/08/2007
Smoke Detector	2nd Inside Blue Wing Exhibit Butterfly Exhibit	Tested	11:53:16 AM	01/08/2007
Smoke Detector	2nd Inside Lighting Exhibit	Tested	12:03:57 PM	01/08/2007
Smoke Detector	2nd Inside Lighting Exhibit	Tested	12:04:31 PM	01/08/2007
Smoke Detector	2nd Inside Lighting Exhibit	Tested	12:05:38 PM	01/08/2007
Smoke Detector	2nd Inside Lighting Exhibit	Tested	12:07:15 PM	01/08/2007

Building: xxxxxxxxxxxxxxxx

Control Panel: 2 - Gamewell FLEX
404

The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other. Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred.

Device Type	Location	Service	Time	Date
<i>Passed</i>				
Control				
Control Panel	1st Inside Planterium Exhibit Sub Panel	Tested	9:04:23 AM	01/08/2007
Initiating				
Heat Detector	1st Inside Planterium Exhibit 14 units	Tested	9:03:45 AM	01/08/2007
Smoke Detector	1st Inside Planterium Exhibit 14 units	Tested	9:02:56 AM	01/08/2007

Inventory & Warranty Report

Generated by: *BuildingReports.com*

Building: xxxxxxxxxxxxxxxxxxxxxxxxxxxxxxx		Control Panel: 1 - Notifier		
<p><i>The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.</i></p>				
Device or Item	Category	% of Inventory	Quantity	
Control Panel	Control	5%	2	
Pull Station	Initiating	17%	7	
Smoke Detector	Initiating	71%	29	
Heat Detector	Initiating	2%	1	
Duct Detector	Initiating	5%	2	
Type	Qty	Model #	Description	Install Date
<i>In Service - 10 Years to 15 Years</i>				
Duct Detector	1			08/01/1996
Duct Detector	1		Photoelectric	08/01/1996
Pull Station	2		Dual Action	08/01/1996
Smoke Detector	28		Photoelectric	08/01/1996
Gamewell				
Pull Station	1		Dual Action	08/01/1996
Notifier				
Control Panel	1			08/01/1996
Pull Station	3		Dual Action	08/01/1996
SimplexGrinnell				
Pull Station	1		Dual Action	08/01/1996

Building: XXXXXXXXXXXXXXXXXXXX

Control Panel: 2 - Gamewell FLEX
404

The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.

Type	Qty	Model #	Description	Install Date
<i>In Service - 10 Years to 15 Years</i>				
Heat Detector	1		Fixed Temperature	08/01/1996
Gamewell				
Control Panel	1	FLEX 404		08/01/1996
Smoke Detector	1		Photoelectric	08/01/1996

Zone Address Report

Generated by: BuildingReports.com

Building: XXXXXXXXXXXXXXXx	Control Panel: 1 - Notifier
-----------------------------------	------------------------------------

The Zone Address Report lists all of the devices and items that have an individual address, or are grouped together under a common zone. The device type, location, and description are included for your reference.

Address	Device Type	Location	Description	ScanID
L7M04	Pull Station	1st Inside Blue Wing Exhibit Inside	Dual Action	03624561
L7M05	Pull Station	1st Inside Blue Wing Exhibit Inside Electric Exhibit	Dual Action	03624569
L7D61	Smoke Detector	1st Inside Computer Place Exhibit Stair #14	Photoelectric	03624562
L7D60	Smoke Detector	1st Inside Blue Wing Exhibit Inside	Photoelectric	03624563
L7D57	Smoke Detector	1st Inside Blue Wing Exhibit Inside Electric Exhibit	Photoelectric	03624564
L7D56	Smoke Detector	1st Inside Blue Wing Inside Computer Place Exhibit	Photoelectric	03624565
L7D55	Smoke Detector	1st Inside Blue Wing Inside Computer Place Exhibit	Photoelectric	03624566
L7D53	Smoke Detector	1st Inside Blue Wing Inside Computer Place Exhibit	Photoelectric	03624567
L7D54	Smoke Detector	1st Inside Blue Wing Inside Computer Place Exhibit	Photoelectric	03624568
L2M47	Smoke Detector	1st Inside Blue Wing Exhibit Main Entrance	Photoelectric	03624553
L2M47	Smoke Detector	1st Inside Blue Wing Exhibit By Mens Room	Photoelectric	03624554
L2M47	Smoke Detector	1st Inside Blue Wing Exhibit Mathematica	Photoelectric	03624555
L2M47	Smoke Detector	1st Inside Blue Wing Exhibit Mathematica	Photoelectric	03624556
L2M47	Smoke Detector	1st Inside Blue Wing Exhibit Mathematica	Photoelectric	03624557
L2M47	Smoke Detector	1st Inside Blue Wing Exhibit by Apollo	Photoelectric	03624558
L2M47	Smoke Detector	1st Inside Blue Wing Exhibit by Apollo	Photoelectric	03624559
L2M47	Smoke Detector	1st Inside Blue Wing Exhibit Outside	Photoelectric	03624560
L2M48	Duct Detector	2nd Inside Blue Wing Exhibit Main Entrance		03624545
L2M48	Duct Detector	2nd Inside Blue Wing Exhibit Stair #9	Photoelectric	03624543
L2M48	Pull Station	2nd Inside Blue Wing Exhibit Stair #9	Dual Action	03624544
L7M03	Pull Station	2nd Inside Lighting Exhibit	Dual Action	03624551
L2M42	Pull Station	2nd Inside Butterfly Exhibit	Dual Action	03624552
L2M48	Pull Station	2nd Inside Blue Wing Exhibit Stair #10	Dual Action	03624546
L7D50	Smoke Detector	2nd Inside Lighting Exhibit	Photoelectric	03624547
L7D51	Smoke Detector	2nd Inside Lighting Exhibit	Photoelectric	03624548
L7D49	Smoke Detector	2nd Inside Lighting Exhibit	Photoelectric	03624549
L7D48	Smoke Detector	2nd Inside Lighting Exhibit	Photoelectric	03624550
L2M48	Smoke Detector	2nd Inside Blue Wing Exhibit Butterfly Exhibit	Photoelectric	03624619

L2M48	Smoke Detector	2nd Inside Blue Wing Exhibit Stair #9	Photoelectric	03624620
L2M48	Smoke Detector	2nd Inside Blue Wing Exhibit Cahners Theater	Photoelectric	03624621
L2M48	Smoke Detector	2nd Inside Blue Wing Exhibit Cahners Theater	Photoelectric	03624622
L2M48	Smoke Detector	2nd Inside Blue Wing Exhibit	Photoelectric	03624623
L2M48	Smoke Detector	2nd Inside Blue Wing Exhibit 3-D Cinema	Photoelectric	03624624
L2M48	Smoke Detector	2nd Inside Blue Wing Exhibit Lighting Exhibit	Photoelectric	03624625
L2M48	Smoke Detector	2nd Inside Blue Wing Exhibit at Stair #10	Photoelectric	03624626
L2M48	Smoke Detector	2nd Inside Blue Wing Exhibit Optical Illusions	Photoelectric	03624627