

Fire Alarm and Life Safety System Inspection Certificate

For

PRIVATE – Customer info
removed from sample report

Framingham, MA 01701

Tested to NFPA 72 Standards

This Inspection was performed in accordance with applicable NFPA Standards. The subsequent pages of this report provide performance measurements, listed ranges of acceptable results, and complete documentation of the inspection. Whenever discrepancies exist between acceptable performance standards and actual test results, notes and/or recommended solutions have been proposed or provided for immediate review and approval.

Inspection Date
Dec 16, 2006

Building: XXXXXXXXXXXXXXXX
Contact: XXXXXXXXXXXXXXXX
Title: Mgr.

Company: Norel Service Company, Inc.
Contact: Joe Nascimento
Title: Tester/Inspector

Executive Summary

Generated by: BuildingReports.com

Building Information								
Building: XXXXXXXXXXXX.	Contact: xxxxxxxxxxxxxxxxxxxx							
Address: XXXXXXXXXXXXXXXX.	Phone: XXXXXXXXXXXXXXXXXXXX							
Address:	Fax:							
City/State/Zip: Framingham, MA 01701	Mobile:							
Country: United States of America	Email: XXXXXXXXXXXXXXXX							
Inspection Performed By								
Company: Norel Service Company, Inc.	Inspector: Joe Nascimento							
Address: 16 Cherry Street	Phone: 617-590-1005							
Address:	Fax:							
City/State/Zip: Cambridge, MA 02139	Mobile:							
Country: United States of America	Email: bonnie@norelservice.com							
System Control Unit								
Manufacturer: Notifier	Inspection Date: 02/11/2006	IDC Style:						
Model Number: 5000	Install Date: 03/18/2004	SLC Style:						
Software Version:	Version Date: 03/12/2004	NAC Style:						
Location: 1st Inside Electrical Closet	Current Protection: Breaker							
Monitoring								
Type: Digital Communicator	Mfg: Silent Knight	Model #: 5104						
Test Time/Date: 4/13/06 11:42:18 AM	Restore Time:							
Inspection Summary								
Category	Total Items		Serviced		Passed		Failed/Other	
	Qty	%	Qty	%	Qty	%	Qty	%
Initiating	85	32%	35	41%	35	100%	0	0%
Supervisory	22	8%	22	100%	22	100%	0	0%
Control	19	7%	11	58%	11	100%	0	0%
Indicating	143	53%	143	100%	143	100%	0	0%
Totals	269	100%	211	78%	211	100%	0	0%
Certification								
Building: XXXXXXXXXXXXXXXX.	Company: Norel Service Company, Inc.							
Contact: XXXXXXXXXXXXXXXX	Inspector: Joe Nascimento							
Signed:	Signed:							

Notes & Recommendations

Generated by: *BuildingReports.com*

Building: XXXXXXXXXXXXXXXXXXXXXXXX		Control Panel: 1 - Notifier 5000		
<p><i>The Notes & Recommendations Report details additional inspection notes made by the Inspectors during the course of the building inspection. Notes are grouped by Category.</i></p>				
ScanID	Note	Device Type	Location	Comment
<i>Control</i>				
01276209	1	Communicator	1st Inside Electrical Closet / FACP RM.	
TROUBLES, ALARMS, AND RESTORALS CAME THROUGH OPERATOR152				
<i>Indicating</i>				
01276578	2	Strobe	2nd Outside Front Of Bldg. (Outside Beacon)	Special Note
Repair has been completed.				

Inspection & Testing

Generated by: BuildingReports.com

Building: XXXXXXXXXXXXXXXXXXXXX.	Control Panel: 1 - Notifier 5000
----------------------------------	----------------------------------

The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other. Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred.

Device Type	Location	Service	Time	Date
<i>Passed</i>				
Control				
Annunciator	2nd Near Elevator Lobby	Tested	11:52:14 AM	02/11/2006
Battery	1st Inside FACP (2 Batteries)	Visually Checked	9:31:43 AM	02/11/2006
Battery	1st Inside Dialer	Tested	12:10:02 PM	02/11/2006
Battery	1st Inside Power Booster (2 Batteries)	Tested	7:46:45 AM	12/16/2006
Battery	4th Above Booster Panel	Tested	10:36:43 AM	02/11/2006
Battery	4th Inside Bottom Booster Panel	Tested	10:37:27 AM	02/11/2006
Communicator	1st Inside Electrical Closet / FACP RM.	Tested	11:42:18 AM	04/13/2006
Control Panel	1st Inside Electrical Closet	Tested	9:30:58 AM	02/11/2006
Expander Panel	1st Inside Electrical Closet / FACP Rm.	Tested	7:46:37 AM	12/16/2006
Expander Panel	4th Inside Telephone Room	Tested	10:34:42 AM	02/11/2006
Expander Panel	4th Inside Telephone Room	Tested	10:37:17 AM	02/11/2006
Indicating				
Horn/Strobe	1st Beside Stairwell #1	Tested	11:29:52 AM	02/11/2006
Horn/Strobe	1st Passenger Elevator Hallway	Tested	11:43:02 AM	02/11/2006
Horn/Strobe	1st Inside Stairwell #1	Tested	7:47:09 AM	12/16/2006
Horn/Strobe	1st At Elevator Lobby	Tested	7:47:21 AM	12/16/2006
Horn/Strobe	1st Inside Stairwell #2	Tested	7:47:36 AM	12/16/2006
Horn/Strobe	1st Hallway By Stairwell #2	Tested	7:47:44 AM	12/16/2006
Horn/Strobe	1st Between Men's & Women' s Room	Tested	7:48:03 AM	12/16/2006
Horn/Strobe	1st Hallway Near Restrooms	Tested	7:48:11 AM	12/16/2006
Horn/Strobe	1st Inside Cafeteria/ Room#120	Tested	7:48:30 AM	12/16/2006
Horn/Strobe	1st At Loading Dock	Tested	7:48:39 AM	12/16/2006
Horn/Strobe	1st Across From Mail Room	Tested	7:48:48 AM	12/16/2006
Horn/Strobe	1st Inside Mechanical Room	Tested	7:49:18 AM	12/16/2006
Horn/Strobe	1st Inside Mechanical Room By Entrance	Tested	7:49:25 AM	12/16/2006
Horn/Strobe	1st Inside Mechanical Room By Rm. #107	Tested	7:49:35 AM	12/16/2006
Horn/Strobe	1st Hall Near Cafeteria	Tested	7:49:42 AM	12/16/2006
Horn/Strobe	1st Suite #100 Near Entrance	Tested	7:49:50 AM	12/16/2006
Horn/Strobe	1st Suite #100 Near Side Exit	Tested	7:50:11 AM	12/16/2006
Horn/Strobe	1st Suite #100 Outside Break Room	Tested	7:51:16 AM	12/16/2006
Horn/Strobe	1st Suite #100 Inside Conference Room	Tested	7:51:28 AM	12/16/2006
Horn/Strobe	1st Suite #100 Main Office Area	Tested	7:51:42 AM	12/16/2006
Horn/Strobe	2nd By Stairwell #1	Tested	7:51:58 AM	12/16/2006
Horn/Strobe	2nd By Vaccine And Antigen Suite	Tested	7:52:03 AM	12/16/2006
Horn/Strobe	2nd Beside Room #246F	Tested	7:52:10 AM	12/16/2006
Horn/Strobe	2nd Beside Room #244	Tested	7:52:17 AM	12/16/2006
Horn/Strobe	2nd Beside Rest room	Tested	7:52:23 AM	12/16/2006
Horn/Strobe	2nd Front Office Area	Tested	7:52:50 AM	12/16/2006

Device Type	Location	Service	Time	Date
Horn/Strobe	2nd At Main Entrance	Tested	7:52:58 AM	12/16/2006
Horn/Strobe	2nd Near Suite #210	Tested	7:53:03 AM	12/16/2006
Horn/Strobe	2nd Near Suite #200	Tested	7:53:09 AM	12/16/2006
Horn/Strobe	2nd Outside Stairwell #2	Tested	7:53:16 AM	12/16/2006
Horn/Strobe	3rd Near Front Stairs	Tested	8:02:18 AM	12/16/2006
Horn/Strobe	3rd Near Stairwell #2	Tested	8:02:25 AM	12/16/2006
Horn/Strobe	3rd Beside Stairwell #2	Tested	8:02:31 AM	12/16/2006
Horn/Strobe	3rd Inside Stairwell #2	Tested	8:02:42 AM	12/16/2006
Horn/Strobe	3rd Between Restrooms	Tested	8:02:47 AM	12/16/2006
Horn/Strobe	3rd Beside Stairwell #1	Tested	8:03:05 AM	12/16/2006
Horn/Strobe	3rd Inside Stairwell #1	Tested	8:03:17 AM	12/16/2006
Horn/Strobe	3rd Inside Suite#310 Front Area	Tested	8:03:24 AM	12/16/2006
Horn/Strobe	3rd Inside Suite#310 Front Area	Tested	8:03:29 AM	12/16/2006
Horn/Strobe	3rd Inside Suite#310 By Equipment Rm.	Tested	8:03:38 AM	12/16/2006
Horn/Strobe	3rd Inside Suite#310 By Lunch Rm.	Tested	8:03:44 AM	12/16/2006
Horn/Strobe	3rd Inside Suite#310 Office Area	Tested	8:03:58 AM	12/16/2006
Horn/Strobe	3rd Inside Suite#310 By Storage Rm.	Tested	8:04:25 AM	12/16/2006
Horn/Strobe	3rd Inside Suite#310 By Autoclave Rm.	Tested	8:04:32 AM	12/16/2006
Horn/Strobe	3rd Inside Suite#310 In Lab #327	Tested	8:04:39 AM	12/16/2006
Horn/Strobe	3rd Inside Suite#310 In Lab #325	Tested	8:04:49 AM	12/16/2006
Horn/Strobe	3rd Inside Suite#310 In Lab #320	Tested	8:04:55 AM	12/16/2006
Horn/Strobe	3rd Beside Suite#300	Tested	8:05:01 AM	12/16/2006
Horn/Strobe	3rd Inside Suite#300 Receptionist Area	Tested	8:05:07 AM	12/16/2006
Horn/Strobe	3rd Inside Suite#300 Supply Area	Tested	8:05:14 AM	12/16/2006
Horn/Strobe	3rd Inside Suite#300 Near Conference Rm.	Tested	8:05:26 AM	12/16/2006
Horn/Strobe	3rd Inside Suite#300 Near Elevator Exit	Tested	8:05:32 AM	12/16/2006
Horn/Strobe	3rd Inside Suite#300 Computer Rm.	Tested	8:05:43 AM	12/16/2006
Horn/Strobe	3rd Inside Suite#300 Near Conference Rm.	Tested	8:05:50 AM	12/16/2006
Horn/Strobe	3rd Inside Suite#300 Office Area	Tested	8:05:55 AM	12/16/2006
Horn/Strobe	3rd Inside Suite#300 Office Area	Tested	8:06:01 AM	12/16/2006
Horn/Strobe	3rd Inside Suite#300 Near Break Rm.	Tested	8:06:07 AM	12/16/2006
Horn/Strobe	3rd Inside Suite#300 Conference Rm.	Tested	8:06:15 AM	12/16/2006
Horn/Strobe	3rd Inside Suite#300 Office Area	Tested	8:06:21 AM	12/16/2006
Horn/Strobe	3rd Inside Suite#300 Office Area	Tested	8:06:29 AM	12/16/2006
Horn/Strobe	3rd Inside Suite#320 Office Area	Tested	8:06:35 AM	12/16/2006
Horn/Strobe	4th Beside Stairwell #1	Tested	7:57:38 AM	12/16/2006
Horn/Strobe	4th Hallway Near Suite #420	Tested	7:57:44 AM	12/16/2006
Horn/Strobe	4th Between Restrooms	Tested	7:57:50 AM	12/16/2006
Horn/Strobe	4th At Elevator Lobby	Tested	7:58:16 AM	12/16/2006
Horn/Strobe	4th Beside Stairwell #2	Tested	7:58:23 AM	12/16/2006
Horn/Strobe	4th Hallway Near Stairwell #2	Tested	7:58:42 AM	12/16/2006
Horn/Strobe	4th Hallway By Rear Exit of Suite #420	Tested	7:58:48 AM	12/16/2006
Horn/Strobe	4th Inside Suite #420 by Receptionist Desk	Tested	7:58:54 AM	12/16/2006
Horn/Strobe	4th Inside Suite #420 Near Conference Rms.	Tested	7:59:18 AM	12/16/2006
Horn/Strobe	4th Inside Suite #420 In Conference Rm. A	Tested	7:59:24 AM	12/16/2006
Horn/Strobe	4th Inside Suite #420 In Training Rm.	Tested	7:59:29 AM	12/16/2006
Horn/Strobe	4th Inside Suite #420 File Area	Tested	7:59:35 AM	12/16/2006
Horn/Strobe	4th Inside Suite #420 Cubicle Area	Tested	7:59:41 AM	12/16/2006
Horn/Strobe	4th Inside Suite #410 Waiting Area	Tested	7:59:57 AM	12/16/2006
Horn/Strobe	4th Inside Suite #410 Hall	Tested	8:00:03 AM	12/16/2006
Horn/Strobe	4th Inside Suite #410 Cubicle Area	Tested	8:00:15 AM	12/16/2006
Horn/Strobe	4th Inside Suite #410 Cubicle Area	Tested	8:00:20 AM	12/16/2006

Device Type	Location	Service	Time	Date
Horn/Strobe	4th Inside Suite #410 Cubicle Area	Tested	8:00:26 AM	12/16/2006
Horn/Strobe	4th Inside Suite #410 Near Copy Rm.	Tested	8:00:43 AM	12/16/2006
Horn/Strobe	4th Inside Suite #410 Hall Near Data Center	Tested	8:00:49 AM	12/16/2006
Horn/Strobe	4th Inside Suite #410 By Telephone Rm.	Tested	8:00:56 AM	12/16/2006
Horn/Strobe	4th Inside Suite #410 Rear Area	Tested	8:01:03 AM	12/16/2006
Horn/Strobe	4th Inside Suite #400 Front Area	Tested	8:01:13 AM	12/16/2006
Horn/Strobe	4th Inside Suite #400 Hallway	Tested	8:01:24 AM	12/16/2006
Horn/Strobe	4th Inside Suite #400 Cubicle Area	Tested	8:01:31 AM	12/16/2006
Horn/Strobe	4th Inside Suite #400 Break Rm,	Tested	8:01:42 AM	12/16/2006
Horn/Strobe	4th Inside Suite #400 Near Electric Rm.	Tested	8:01:51 AM	12/16/2006
Horn/Strobe	4th Inside Suite #400 Near Electric Rm.	Tested	8:02:00 AM	12/16/2006
Horn/Strobe	4th Inside Stairwell #2	Tested	8:07:01 AM	12/16/2006
Horn/Strobe	5th Beside Stairwell #2	Tested	7:53:26 AM	12/16/2006
Horn/Strobe	5th Near Stairwell #2	Tested	7:53:32 AM	12/16/2006
Horn/Strobe	5th Inside Suite #510	Tested	7:53:39 AM	12/16/2006
Horn/Strobe	5th Inside Suite #510 Hallway	Tested	7:53:45 AM	12/16/2006
Horn/Strobe	5th Inside Suite #510 Hallway	Tested	7:53:51 AM	12/16/2006
Horn/Strobe	5th Inside Suite #510 Hallway	Tested	7:53:57 AM	12/16/2006
Horn/Strobe	5th Inside Suite #510 Hallway	Tested	7:54:03 AM	12/16/2006
Horn/Strobe	5th Rear Hall Of Suite #510 .	Tested	7:54:19 AM	12/16/2006
Horn/Strobe	5th Inside Suite #500 By Receptionist Desk	Tested	7:54:25 AM	12/16/2006
Horn/Strobe	5th Inside Suite #500	Tested	7:54:35 AM	12/16/2006
Horn/Strobe	5th Inside Suite #500	Tested	7:54:42 AM	12/16/2006
Horn/Strobe	5th Inside Suite #500 Cubicle Area	Tested	7:54:55 AM	12/16/2006
Horn/Strobe	5th Inside Suite #500 Cubicle Area	Tested	7:55:03 AM	12/16/2006
Horn/Strobe	5th Inside Suite #500	Tested	7:55:10 AM	12/16/2006
Horn/Strobe	5th Inside Suite #500 Computer Rm.	Tested	7:55:19 AM	12/16/2006
Horn/Strobe	5th Beside Stairwell #1	Tested	7:55:26 AM	12/16/2006
Horn/Strobe	5th Inside Stairwell #1	Tested	7:55:32 AM	12/16/2006
Horn/Strobe	5th Inside Main Hallway	Tested	7:55:37 AM	12/16/2006
Horn/Strobe	5th Between Restrooms	Tested	7:55:43 AM	12/16/2006
Horn/Strobe	5th Inside Suite #520	Tested	7:56:00 AM	12/16/2006
Horn/Strobe	5th Inside Suite #520	Tested	7:56:17 AM	12/16/2006
Horn/Strobe	5th Inside Suite #520 By Storage Rm.	Tested	7:56:28 AM	12/16/2006
Horn/Strobe	5th Inside Suite #520 In break Rm.	Tested	7:56:35 AM	12/16/2006
Horn/Strobe	5th Inside Suite #520 In Conference Rm.	Tested	7:56:42 AM	12/16/2006
Horn/Strobe	5th Inside Suite #520	Tested	7:56:48 AM	12/16/2006
Horn/Strobe	5th Inside Suite #520	Tested	7:56:57 AM	12/16/2006
Horn/Strobe	5th Inside Stairwell #2	Tested	7:57:02 AM	12/16/2006
Strobe	1st Inside Mens Locker Room	Tested	11:39:03 AM	02/11/2006
Strobe	1st Inside Womens Locker Room	Tested	7:48:23 AM	12/16/2006
Strobe	1st Suite #100 Break Room	Tested	7:49:58 AM	12/16/2006
Strobe	2nd Inside Mens Room	Tested	7:52:29 AM	12/16/2006
Strobe	2nd Inside Womens Room	Tested	7:52:43 AM	12/16/2006
Strobe	2nd Outside Front Of Bldg. (Outside Beacon)	Replaced	8:07:08 AM	12/16/2006
Strobe	3rd Inside Mens Room	Tested	8:02:53 AM	12/16/2006
Strobe	3rd Inside Womens Room	Tested	8:02:58 AM	12/16/2006
Strobe	3rd Inside Suite#310 In Lunch Rm.	Tested	8:03:50 AM	12/16/2006
Strobe	3rd Inside Suite#310 Conference Rm.	Tested	8:04:06 AM	12/16/2006
Strobe	3rd Inside Suite#300 Conference Rm.	Tested	8:05:20 AM	12/16/2006
Strobe	4th Inside Mens Room	Tested	7:58:01 AM	12/16/2006
Strobe	4th Inside Womens Room	Tested	7:58:08 AM	12/16/2006

Device Type	Location	Service	Time	Date
Strobe	4th Inside Suite #420 Rear of Cubicle Area	Tested	7:59:49 AM	12/16/2006
Strobe	4th Inside Suite #410 Washington Conference Rm.	Tested	8:00:32 AM	12/16/2006
Strobe	4th Inside Suite #410 Madison Conference Rm.	Tested	8:00:38 AM	12/16/2006
Strobe	4th Inside Suite #400 Conference Rm.	Tested	8:01:18 AM	12/16/2006
Strobe	4th Inside Suite #400 Copy Rm.	Tested	8:01:37 AM	12/16/2006
Strobe	5th Inside Suite #510 Conference Rm.	Tested	7:54:09 AM	12/16/2006
Strobe	5th Inside Suite #500 In Conference Rm.	Tested	7:54:30 AM	12/16/2006
Strobe	5th Inside Suite #500 Break Rm.	Tested	7:54:48 AM	12/16/2006
Strobe	5th Inside Mens Room	Tested	7:55:49 AM	12/16/2006
Strobe	5th Inside Womens Room	Tested	7:55:55 AM	12/16/2006
Strobe	5th Inside Suite #520 Fax/Copy Rm.	Tested	7:56:10 AM	12/16/2006
Strobe	5th Inside Suite #500 Computer Rm.	Tested	7:57:09 AM	12/16/2006
Strobe	5th Inside Suite #510 Teledata Rm.	Tested	7:57:16 AM	12/16/2006
Initiating				
Pull Station	1st Inside Cafeteria/ Room#120	Tested	11:30:27 AM	02/11/2006
Pull Station	1st At Loading Dock	Tested	11:36:40 AM	02/11/2006
Pull Station	1st Inside Mechanical Room	Tested	7:49:12 AM	12/16/2006
Pull Station	2nd At Main Entrance	Tested	11:05:29 AM	02/11/2006
Pull Station	2nd By Stairwell #1	Tested	11:14:22 AM	02/11/2006
Pull Station	3rd Inside Suite#300 Computer Rm.	Tested	10:59:58 AM	02/11/2006
Pull Station	4th Beside Stairwell #1	Tested	10:24:11 AM	02/11/2006
Pull Station	5th Beside Stairwell #1	Tested	9:44:16 AM	02/11/2006
Smoke Detector	1st Inside Electrical Closet / FACP RM.	Tested/Cleaned	9:32:01 AM	02/11/2006
Smoke Detector	1st At Elevator Lobby	Tested	11:51:02 AM	02/11/2006
Smoke Detector	1st At Freight Elevator Lobby	Tested	12:00:10 PM	02/11/2006
Smoke Detector	1st Inside Telephone Rm. in Mgmt. Office	Tested/Cleaned	7:49:05 AM	12/16/2006
Smoke Detector	2nd At Passenger Elevator Lobby	Tested	11:29:43 AM	02/11/2006
Smoke Detector	2nd At Freight Elevator Lobby	Tested	11:58:25 AM	02/11/2006
Smoke Detector	3rd At Passenger Elevator Lobby	Tested	11:03:14 AM	02/11/2006
Smoke Detector	3rd At Freight Elevator Lobby	Tested	12:06:59 PM	02/11/2006
Smoke Detector	3rd Inside Suite#320 Telephone Rm.	Tested	8:06:48 AM	12/16/2006
Smoke Detector	4th At Elevator Lobby	Tested	10:15:30 AM	02/11/2006
Smoke Detector	4th Inside Suite #420 Copy Rm. (Remote LED)	Tested	10:18:58 AM	02/11/2006
Smoke Detector	4th At Freight Elevator Lobby	Tested	12:04:07 PM	02/11/2006
Smoke Detector	5th At Elevator Lobby	Tested	9:39:34 AM	02/11/2006
Smoke Detector	5th At Freight Elevator Lobby	Tested	12:05:23 PM	02/11/2006
Waterflow Switch	1st Inside Stairwell #1	Tested	9:25:31 AM	04/13/2006
Waterflow Switch	1st Hall by Passenger Elevator Lobby	Tested	9:39:28 AM	04/13/2006
Waterflow Switch	1st Main Flow	Tested	10:31:49 AM	04/13/2006
Waterflow Switch	1st Inside Mechanical Room By Rm. #105 (Inspector's Test)	Tested	10:54:44 AM	04/13/2006
Waterflow Switch	1st BASEMENT BY WOMENS	Tested	11:07:05 AM	04/13/2006
Waterflow Switch	2nd Inside Stairwell #1	Tested	9:22:28 AM	04/13/2006
Waterflow Switch	2nd Inside Stairwell #2	Tested	9:56:26 AM	04/13/2006
Waterflow Switch	3rd Inside Stairwell #1	Tested	9:04:16 AM	04/13/2006
Waterflow Switch	3rd Inside Stairwell #2	Tested	9:53:25 AM	04/13/2006
Waterflow Switch	4th Inside Stairwell #1	Tested	9:00:47 AM	04/13/2006
Waterflow Switch	4th Inside Stairwell #2	Tested	9:50:37 AM	04/13/2006
Waterflow Switch	5th Inside Stairwell #1	Tested	8:56:54 AM	04/13/2006
Waterflow Switch	5th Inside Stairwell #2	Tested	9:47:36 AM	04/13/2006

Device Type	Location	Service	Time	Date
Supervisory				
Air Pressure Switch	1st On The Main	Tested	10:01:38 AM	04/13/2006
Tamper Switch	1st Inside Stairwell #1	Tested	9:24:05 AM	04/13/2006
Tamper Switch	1st Hallway Near Sprinkler Rm.	Tested	9:29:59 AM	04/13/2006
Tamper Switch	1st Outside Stairwell #1	Tested	9:31:54 AM	04/13/2006
Tamper Switch	1st Hall by Passenger Elevator Lobby	Tested	9:37:52 AM	04/13/2006
Tamper Switch	1st Before Backflow	Tested	9:59:19 AM	04/13/2006
Tamper Switch	1st After Backflow	Tested	9:59:40 AM	04/13/2006
Tamper Switch	1st Main Riser	Tested	10:28:35 AM	04/13/2006
Tamper Switch	1st Outside Stairwell #2	Tested	10:40:32 AM	04/13/2006
Tamper Switch	1st Outside Stairwell #2	Tested	10:41:23 AM	04/13/2006
Tamper Switch	1st Inside Mechanical Room By Rm. #107	Tested	10:56:14 AM	04/13/2006
Tamper Switch	1st BASEMENT TAMPER BY WOMENS ROOM	Tested	11:07:35 AM	04/13/2006
Tamper Switch	2nd Outside Of Bldg. (Outside PIV)	Tested	11:53:57 AM	02/11/2006
Tamper Switch	2nd Inside Stairwell #1	Tested	9:10:05 AM	04/13/2006
Tamper Switch	2nd Inside Stairwell #2	Tested	9:54:40 AM	04/13/2006
Tamper Switch	3rd Inside Stairwell #1	Tested	9:02:18 AM	04/13/2006
Tamper Switch	3rd Inside Stairwell #2	Tested	9:51:49 AM	04/13/2006
Tamper Switch	4th Inside Stairwell #1	Tested	8:58:48 AM	04/13/2006
Tamper Switch	4th Inside Stairwell #2	Tested	9:48:46 AM	04/13/2006
Tamper Switch	5th Inside Stairwell #1	Tested	8:54:10 AM	04/13/2006
Tamper Switch	5th Inside Stairwell #1	Tested	8:55:25 AM	04/13/2006
Tamper Switch	5th Inside Stairwell #2	Tested	9:45:49 AM	04/13/2006
Untested				
Control				
Battery	2nd Above Booster Panel (2 Batteries)			
Battery	3rd Inside Booster Panel			
Battery	4th Inside Booster Panel (2 Batteries)			
Battery	5th Above Dialer (2 Batteries)			
Expander Panel	2nd Inside Telephone Room			
Expander Panel	3rd Inside Telephone Room			
Expander Panel	4th Inside Suite #400 Electric Rm.			
Expander Panel	5th Inside Telephone Room			
Initiating				
Duct Detector	1st Inside Mechanical Room (AHU-4 SUPPLY)			
Duct Detector	1st Inside Mechanical Room (AHU-5 SUPPLY)			
Duct Detector	1st Hallway Near Mail Room (AHU-3 SUPPLY)			
Duct Detector	1st Hallway Near Mail Room (AHU-4 RETURN)			
Duct Detector	4th Inside Suite #400 Near Electric Rm. (RTU-7 RETURN)			
Duct Detector	4th Inside Suite #400 Near Electric Rm. (RTU-5 SUPPLY)			
Duct Detector	4th Inside Suite #400 Near Electric Rm. (RTU-3 RETURN)			
Duct Detector	4th Inside Suite #420 Inside Mailroom (RTU-6 SUPPLY)			
Duct Detector	5th Top Of Stairwell #2 (RTU-#3 SUPPLY)			
Duct Detector	5th Inside Suite #510 Fax Rm. (RTU-4 SUPPLY)			
Duct Detector	5th Inside Suite #520 In Conference Rm. (RTU - 2 RETURN)			

Device Type	Location	Service	Time	Date
Duct Detector	5th Inside Suite #520 In Conference Rm. (RTU - 2 SUPPLY)			
Duct Detector	5th Inside Suite #520 By Fax/Copy Rm. (RTU -1 RETURN)			
Duct Detector	5th Inside Suite #520 By Fax/Copy Rm. (RTU -1 SUPPLY)			
Pull Station	1st Inside Mechanical Room By Rm. #105			
Pull Station	1st Near Suite #130			
Pull Station	2nd Outside Stairwell #2			
Pull Station	2nd Beside Rest room / Elevator Lobby			
Pull Station	3rd Beside Stairwell #2			
Pull Station	3rd Beside Stairwell #1			
Pull Station	4th Beside Stairwell #2			
Pull Station	5th Beside Stairwell #2			
Smoke Detector	1st Inside Stairwell #2			
Smoke Detector	1st Inside Elevator Machine Rm. #1			
Smoke Detector	1st Inside Main Electric Closet			
Smoke Detector	1st Inside Elevator Machine Room #2			
Smoke Detector	1st Inside Telephone/Storage Room			
Smoke Detector	1st Inside Stairwell #1			
Smoke Detector	1st Suite #100 Telephone Room			
Smoke Detector	1st Inside Mechanical Room			
Smoke Detector	2nd Inside Electrical Room			
Smoke Detector	2nd Inside Telephone Room			
Smoke Detector	2nd In Storage Rm. Across from Room. #230			
Smoke Detector	3rd Inside Electrical Room			
Smoke Detector	3rd Inside Telephone Room			
Smoke Detector	3rd Inside Suite#310 In Storage Rm.			
Smoke Detector	3rd Inside Suite#310 In telephone Closet.			
Smoke Detector	3rd Inside Suite#300 Computer Rm.			
Smoke Detector	3rd Inside Suite#300 Computer Rm.			
Smoke Detector	4th Inside Suite #400 Teledata Rm (Remote LED)			
Smoke Detector	4th Inside Suite #400 Electric Rm. (Remote LED)			
Smoke Detector	4th Inside Suite #420 Server Rm. (Remote LED)			
Smoke Detector	4th Inside Suite #410 Telephone Rm. (Remote LED)			
Smoke Detector	4th Inside Telephone Room			
Smoke Detector	4th Inside Electrical Room			
Smoke Detector	5th Top Of Stairwell #1			
Smoke Detector	5th Inside Suite #500 Teledata Rm.			
Smoke Detector	5th Inside Electrical Room			
Smoke Detector	5th Inside Telephone Room			
Smoke Detector	5th Top Of Stairwell #2			

Time, Temperature & Level Testing

Generated by: BuildingReports.com

Building: XXXXXXXXXX.		Control Panel: 1 - Notifier 5000				
<p><i>The Time, Temperature, & Level Testing section details the measurements taken from various devices that are designed to respond in a certain amount of time, respond at a certain temperature, or respond within the acceptable range of volume or level. Items are grouped by Passed or Failed/Other.</i></p>						
Type	Location	Comment	Sec	Deg	Lvl	ScanID
<i>Passed</i>						
Waterflow Switch						
	1st Inside Stairwell #1		35 sec	n/a	n/a	01276325
	1st Hall by Passenger Elevator Lobby		35 sec	n/a	n/a	01276565
	1st Inside Mechanical Room By Rm. #105 (Inspector's Test)		35 sec	n/a	n/a	01276363
	1st BASEMENT BY WOMENS		40 sec	n/a	n/a	03623196
	2nd Inside Stairwell #1		30 sec	n/a	n/a	01276466
	2nd Inside Stairwell #2		.45 sec	n/a	n/a	01276576
	3rd Inside Stairwell #1		40 sec	n/a	n/a	01276460
	3rd Inside Stairwell #2		45 sec	n/a	n/a	01276574
	4th Inside Stairwell #1		65 sec	n/a	n/a	01276452
	4th Inside Stairwell #2		50 sec	n/a	n/a	01276571
	5th Inside Stairwell #1		45 sec	n/a	n/a	01276448
	5th Inside Stairwell #2		50 sec	n/a	n/a	01276569

Inventory & Warranty Report

Generated by: BuildingReports.com

Building: XXXXXXXXXXXXXXXXX		Control Panel: 1 - Notifier 5000		
<p><i>The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.</i></p>				
Device or Item	Category	% of Inventory	Quantity	
Smoke Detector	Initiating	16%	42	
Pull Station	Initiating	6%	16	
Duct Detector	Initiating	5%	14	
Expander Panel	Control	3%	7	
Battery	Control	3%	9	
Control Panel	Control	0%	1	
Horn/Strobe	Indicating	43%	117	
Strobe	Indicating	10%	26	
Annunciator	Control	0%	1	
Tamper Switch	Supervisory	8%	21	
Waterflow Switch	Initiating	5%	13	
Air Pressure Switch	Supervisory	0%	1	
Communicator	Control	0%	1	
Type	Qty	Model #	Description	Install Date
<i>In Service - 2 Years to 3 Years</i>				
Duct Detector	6			03/18/2004
Smoke Detector	4		Photoelectric	03/18/2004
Tamper Switch	1			03/18/2004
Waterflow Switch	5			03/18/2004
Fire-Lite				
Expander Panel	1	FCPS-24		03/18/2004
Notifier				
Control Panel	1	5000		03/18/2004
Pull Station	2			03/18/2004
Pull Station	7	BGX-101L		03/18/2004
Smoke Detector	1	2451	Photoelectric	03/18/2004
Potter Electric				
Tamper Switch	1			03/18/2004
Waterflow Switch	1			03/18/2004
Power-Sonic				
Battery	1	PS-1270	Sealed Lead Acid	03/18/2004
System Sensor				
Smoke Detector	3		Photoelectric	03/18/2004
Smoke Detector	13	2451	Photoelectric	03/18/2004
Victaulic				
Tamper Switch	5			03/18/2004
Wheelock				

Horn/Strobe	60			03/18/2004
Strobe	12			03/18/2004
Duct Detector				
Duct Detector	8			03/12/2004
Strobe	1			03/12/2004
Tamper Switch	1			03/12/2004
Waterflow Switch	2			03/12/2004
Notifier				
Annunciator	1		Other	03/12/2004
Expander Panel	6	FCPS-24		03/12/2004
Pull Station	6			03/12/2004
Pull Station	1	Bgx-1011		03/12/2004
Smoke Detector	5		Photoelectric	03/12/2004
Smoke Detector	2	2451	Photoelectric	03/12/2004
Smoke Detector	1	SFP-851	Photoelectric	03/12/2004
Potter Electric				
Air Pressure Switch	1	PS40-2A		03/12/2004
Tamper Switch	2	OSYSU- 2		03/12/2004
Waterflow Switch	4			03/12/2004
Waterflow Switch	1	VSR-F		03/12/2004
Silent Knight				
Communicator	1	5104	Digital Communicator	03/12/2004
System Sensor				
Smoke Detector	13	2451	Photoelectric	03/12/2004
Victaulic				
Tamper Switch	11			03/12/2004
Wheelock				
Horn/Strobe	57			03/12/2004
Strobe	13			03/12/2004
Yuasa				
Battery	3		Sealed Lead Acid	03/12/2004
<i>In Service - 3 Years to 5 Years</i>				
Yuasa				
Battery	3	NP7-12	Sealed Lead Acid	12/17/2003
Powerson				
Battery	1	MF12-7	Sealed Lead Acid	12/02/2003
<i>In Service - 5 Years to 10 Years</i>				
Power-Sonic				
Battery	1	PS-1 2260 F2	Sealed Lead Acid	07/13/2001

Zone Address Report

Generated by: BuildingReports.com

Building: XXXXXXXXXXXXXXXXXXXX	Control Panel: 1 - Notifier 5000
---------------------------------------	---

The Zone Address Report lists all of the devices and items that have an individual address, or are grouped together under a common zone. The device type, location, and description are included for your reference.

Address	Device Type	Location	Description	ScanID
M1-20	Air Pressure Switch	1st On The Main		01276352
M1-64	Duct Detector	1st Inside Mechanical Room (AHU-4 SUPPLY)		01276359
M1-66	Duct Detector	1st Inside Mechanical Room (AHU-5 SUPPLY)		01276360
M1-60	Duct Detector	1st Hallway Near Mail Room (AHU-3 SUPPLY)		01276347
M1-62	Duct Detector	1st Hallway Near Mail Room (AHU-4 RETURN)		01276348
M1-41	Pull Station	1st Near Suite #130		01276337
M1-34	Pull Station	1st Inside Cafeteria/ Room#120		01276343
M1-42	Pull Station	1st Inside Mechanical Room By Rm. #105		01276364
M1-25	Pull Station	1st At Loading Dock		01276345
M1-43	Pull Station	1st Inside Mechanical Room		01276356
D1-19	Smoke Detector	1st Inside Telephone Rm. in Mgmt. Office	Photoelectric	01276355
D1-10	Smoke Detector	1st Suite #100 Telephone Room	Photoelectric	01276372
D1-9	Smoke Detector	1st Inside Mechanical Room	Photoelectric	01276373
D1-33	Smoke Detector	1st Inside Electrical Closet / FACP RM.	Photoelectric	01276211
D1-31	Smoke Detector	1st Inside Main Electric Closet	Photoelectric	01276318
D1-40	Smoke Detector	1st Inside Stairwell #2	Photoelectric	01276335
D1-44	Smoke Detector	1st At Freight Elevator Lobby	Photoelectric	01276320
D1-42	Smoke Detector	1st Inside Elevator Machine Room #2	Photoelectric	01276321
D1-32	Smoke Detector	1st Inside Telephone/Storage Room	Photoelectric	01276322
D1-28	Smoke Detector	1st Inside Stairwell #1	Photoelectric	01276323
M1-36	Smoke Detector	1st Inside Elevator Machine Rm. #1	Photoelectric	01276328
M1-35	Smoke Detector	1st At Elevator Lobby	Photoelectric	01276329
M1-18	Tamper Switch	1st Outside Stairwell #2		01276332
M1-30	Tamper Switch	1st Outside Stairwell #2		01276333
M1-29	Tamper Switch	1st Inside Stairwell #1		01276326
M1-26	Tamper Switch	1st Outside Stairwell #1		01276327
M1-24	Tamper Switch	1st Before Backflow		01276350
M1-23	Tamper Switch	1st After Backflow		01276351
M1-49	Tamper Switch	1st Hallway Near Sprinkler Rm.		01276344
M1-22	Tamper Switch	1st Main Riser		01276353
M1-59	Tamper Switch	1st Inside Mechanical Room By Rm. #107		01276361
M1-39	Tamper Switch	1st Hall by Passenger Elevator Lobby		01276564
M1-38	Waterflow Switch	1st Hall by Passenger Elevator Lobby		01276565
M1-58	Waterflow Switch	1st Inside Mechanical Room By Rm. #105 (Inspector's Test)		01276363
M1-21	Waterflow Switch	1st Main Flow		01276354
M1-27	Waterflow Switch	1st Inside Stairwell #1		01276325

M1-03	Pull Station	2nd By Stairwell #1		01276382
M1-07	Pull Station	2nd Beside Rest room / Elevator Lobby		01276389
M1-09	Pull Station	2nd At Main Entrance		01276395
M1-11	Pull Station	2nd Outside Stairwell #2		01276400
D1-54	Smoke Detector	2nd In Storage Rm. Across from Room. #230	Photoelectric	01276386
D1-06	Smoke Detector	2nd Inside Electrical Room	Photoelectric	01276377
D1-05	Smoke Detector	2nd Inside Telephone Room	Photoelectric	01276380
D1-04	Smoke Detector	2nd At Freight Elevator Lobby	Photoelectric	01276381
D1-08	Smoke Detector	2nd At Passenger Elevator Lobby	Photoelectric	01276577
M2-49	Strobe	2nd Outside Front Of Bldg. (Outside Beacon)		01276578
M1-12	Tamper Switch	2nd Inside Stairwell #2		01276575
M1-02	Tamper Switch	2nd Inside Stairwell #1		01276465
M1-01	Waterflow Switch	2nd Inside Stairwell #1		01276466
M1-13	Waterflow Switch	2nd Inside Stairwell #2		01276576
M2-36	Pull Station	3rd Inside Suite#300 Computer Rm.		01276550
M2-46	Pull Station	3rd Beside Stairwell #2		01276521
M2-42	Pull Station	3rd Beside Stairwell #1		01276526
D2-39	Smoke Detector	3rd At Freight Elevator Lobby	Photoelectric	01276529
M2-55	Smoke Detector	3rd Inside Suite#310 In Storage Rm.	Photoelectric	01276538
M2-56	Smoke Detector	3rd Inside Suite#310 In telephone Closet.	Photoelectric	01276540
D2-38	Smoke Detector	3rd Inside Suite#300 Computer Rm.	Photoelectric	01276551
D2-37	Smoke Detector	3rd Inside Suite#300 Computer Rm.	Photoelectric	01276552
D2-40	Smoke Detector	3rd Inside Suite#320 Telephone Rm.	Photoelectric	01276562
D2-45	Smoke Detector	3rd At Passenger Elevator Lobby	Photoelectric	01276517
D2-44	Smoke Detector	3rd Inside Electrical Room	Photoelectric	01276461
D2-43	Smoke Detector	3rd Inside Telephone Room	Photoelectric	01276464
M2-40	Tamper Switch	3rd Inside Stairwell #1		01276459
M2-48	Tamper Switch	3rd Inside Stairwell #2		01276573
M2-47	Waterflow Switch	3rd Inside Stairwell #2		01276574
M2-41	Waterflow Switch	3rd Inside Stairwell #1		01276460
D2-90	Battery	4th Inside Booster Panel (2 Batteries)	Sealed Lead Acid	01276511
M2-24	Duct Detector	4th Inside Suite #400 Near Electric Rm. (RTU-7 RETURN)		01276513
M2-70	Duct Detector	4th Inside Suite #400 Near Electric Rm. (RTU-5 SUPPLY)		01276514
M2-23	Duct Detector	4th Inside Suite #400 Near Electric Rm. (RTU-3 RETURN)		01276515
M2-73	Duct Detector	4th Inside Suite #420 Inside Mailroom (RTU-6 SUPPLY)		01276481
D2-90	Expander Panel	4th Inside Suite #400 Electric Rm.		01276510
M2-32	Pull Station	4th Beside Stairwell #2		01276476
M1-42	Pull Station	4th Beside Stairwell #1		01276468
D2-31	Smoke Detector	4th At Elevator Lobby	Photoelectric	01276474
D2-82	Smoke Detector	4th At Freight Elevator Lobby	Photoelectric	01276467
D2-94	Smoke Detector	4th Inside Suite #420 Copy Rm. (Remote LED)	Photoelectric	01276488
D2-93	Smoke Detector	4th Inside Suite #420 Server Rm. (Remote LED)	Photoelectric	01276489
D2-32	Smoke Detector	4th Inside Suite #410 Telephone Rm. (Remote LED)	Photoelectric	01276500

D2-90	Smoke Detector	4th Inside Suite #400 Teledata Rm (Remote LED)	Photoelectric	01276508
D2-89	Smoke Detector	4th Inside Suite #400 Electric Rm. (Remote LED)	Photoelectric	01276509
D2-30	Smoke Detector	4th Inside Electrical Room	Photoelectric	01276453
D2-29	Smoke Detector	4th Inside Telephone Room	Photoelectric	01276456
M2-25	Tamper Switch	4th Inside Stairwell #1		01276451
M2-33	Tamper Switch	4th Inside Stairwell #2		01276570
M2-34	Waterflow Switch	4th Inside Stairwell #2		01276571
M2-26	Waterflow Switch	4th Inside Stairwell #1		01276452
M2-21	Duct Detector	5th Inside Suite #520 By Fax/Copy Rm. (RTU -1 RETURN)		01276433
M2-01	Duct Detector	5th Inside Suite #520 By Fax/Copy Rm. (RTU -1 SUPPLY)		01276434
M2-22	Duct Detector	5th Inside Suite #520 In Conference Rm. (RTU - 2 RETURN)		01276439
M2-02	Duct Detector	5th Inside Suite #520 In Conference Rm. (RTU - 2 SUPPLY)		01276440
M2-04	Duct Detector	5th Inside Suite #510 Fax Rm. (RTU-4 SUPPLY)		01276445
M2-03	Duct Detector	5th Top Of Stairwell #2 (RTU-#3 SUPPLY)		01276567
M2-06	Pull Station	5th Beside Stairwell #1		01276424
M2-05	Pull Station	5th Beside Stairwell #2		01276403
D2-12	Smoke Detector	5th Inside Suite #500 Teledata Rm.	Photoelectric	01276421
D2-08	Smoke Detector	5th At Freight Elevator Lobby	Photoelectric	01276423
D2-19	Smoke Detector	5th At Elevator Lobby	Photoelectric	01276402
M2-11	Smoke Detector	5th Inside Electrical Room	Photoelectric	01276394
M2-07	Smoke Detector	5th Top Of Stairwell #1	Photoelectric	01276447
D2-10	Smoke Detector	5th Inside Telephone Room	Photoelectric	01276376
D2-18	Smoke Detector	5th Top Of Stairwell #2	Photoelectric	01276566
M2-13	Tamper Switch	5th Inside Stairwell #2		01276568
M2- 20	Tamper Switch	5th Inside Stairwell #1		01276449
M2-54	Tamper Switch	5th Inside Stairwell #1		01276450
M2-17	Waterflow Switch	5th Inside Stairwell #1		01276448
M2-12	Waterflow Switch	5th Inside Stairwell #2		01276569